

H.O: #215,6th Cross,2^{na} Stage, Bogadi North, Mysore, Karnataka-570026 Mob: 9986699616, 9483954049 E-mail : <u>springsenvirotechmysore@gmail.com</u> B.O: #39,3^{ra} cross, Ist Main, Nethaji Layout, Vijayanagara IInd Stage, Bangalore-560010

Ref: SET/ATME?AMC/19-20/18

Date : 13-10-2019

The Principal. ATME College , Mellahalli Mysore.

.Dear Sir,

Sub: Servicing of AIR Blowers, motors and Media replacement for Existing STP Equipments of Sand filter and Activated carbon filter of STP at your site.

With reference to the above subject and the discussions held with you regarding the same we are serviced all the STP equipment's and replacement of media for existing STP filters at your site on 06-10-2019.

Sl. No.	Description
1.	Sand media for ACF and PSF all 5 grades = 2000 KG
2.	Activated Carbon 200 kg
3.	Service
4.	General service of all motors and Oil replacement of Air blowers.

The motor, Air blowers and filters are serviced on 06-10-19 and taken the trail run in presence with maintenance department; working is satisfactorily and good running condition.

Conclusion: Satisfactorily working and also covered under free service and next service due date after 6 months.

Yours truly, For SPRINGS/ENVH TECH Krishnamurthy HT PRINCIPAL

ATME College of Engineering 13th KM Mysuru-Kanakapura-Bangalore Road



H.O: #215,6th Cross,2^{na} Stage, Bogadi North, Mysore, Karnataka-570026 Mob: 9986699616, 9483954049 E-mail : <u>springsenvirotechmysore@gmail.com</u> B.O: #39,3^{ra} cross, Ist Main, Nethaji Layout, Vijayanagara IInd Stage, Bangalore-560040

Ref: SET/ATME/AMC/20-21/91

Date : .21-7-2020

The Principal. ATME College , Mellahalli Mysore.

Dear Sir,

Sub: Servicing of AIR Blowers, motors and Media replacement for Existing STP Equipment's of Sand filter and Activated carbon filter of STP at your site.

With reference to the above subject and the discussions held with you regarding the same we are serviced all the STP equipment's and replacement of media for existing STP filters at your site on 15-7-2020.

SI. No.	Description
1.	Sand media for ACF and PSF all 5 grades = 2000 KG
2.	Activated Carbon 200 kg
3.	Service
4.	General service of all motors and Oil replacement of Air blowers.

The motor, Air blowers and filters are serviced on 15-7-2020 and taken the trail run in presence with maintenance department; working is satisfactorily and good running condition.

Conclusion: Satisfactorily working and also covered under free service and next service due date after 6 months.

Yours truly, For SPRINGS ENVIROTECH Krishnamurthy HT RINCIPAL ATME College of Engineering 13th KM Mysuru-Kanakapura-Bangalore Road Mellahalli Mysuru-570 028